



NOTE:

WALL BOARD JOINTS ON SINGLE LAYER, OR THE FACE LAYER ON TWO LAYER APPLICATIONS, SHALL NOT OCCUR WITHIN 12" OF THE CORNERS OF DOOR FRAMES UNLESS CONTROL JOINTS ARE INSTALLED AT THE CORNERS.

TEST REF.

WHI 651-0318-1

SCALE: NONE	CONTROL JOINT AT DOOR	
DATE: 2001	NATIONAL GYPSUM COMPANY	DETAIL 09250_23