



093 E-Z Strip® Vinyl Expansion Control Joint

Applicable Standards and References

ASTM C840
ASTM C844
Gypsum Association GA-216
Gypsum Association GA-234 (Fire-Resistant Applications)

Recommendations

Installation of Phillips E-Z Strip® Expansion Control Joints should be consistent with methods and requirements described in the noted standards and references or as modified below.

Joint location – Ceilings:

Gypsum wallboard: Maximum single dimension 50 ft with a maximum area of 2,500 sq. feet.

Joint location – Partitions:

Maximum single dimension between vertical joints should not exceed 30 ft for drywall.

Door or window frames are preferred areas for installing joints. These are high stress points and allow for easy application.

Application

Framing: The framing behind the expansion control joint should not be continuous. In partitions, place two studs spaced approximately 3/8" to 1/2" apart, where the joint occurs. This allows each leg of the joint to be attached over separate studs. The location of the joint in the ceilings should occur at high stress points such as between light fixtures, heat outlets or air diffusers. Where ceilings have a structural wood carrying beam flush with ceiling joints, the joint should be placed directly below and parallel to the carrying beam.

Fasteners: The Phillips E-Z Strip® Expansion Control Joint should be applied with 1/2" or 9/16" staples (Duo Fast No. 5016, No. 6018 or equal). Staples should be spaced not to exceed 6" o.c. along each leg. Staples should be driven either between or across holes with crown at 45° angle from the long dimension of the joint. When butting two pieces of the joint, the crown of the staple should run parallel to the joint with one leg piercing each piece of material. The expansion control joint should fit snug against the substrate. Drive additional staples if required to snug flanges against the base surface.

Finishing

Wallboard: After stapling the Phillips E-Z Strip® Expansion Control Joint in place, apply a first coat of joint compound and allow to dry before applying finishing coat(s) of joint compound.

Application of joint compound should be continuous over the flexible portion of the joint. Material must be troweled tight over screed to remove all material from face of screed. This is necessary to obtain a clean edge when removing flexible vinyl strip.

Stripping: Flexible strip is easily removed after joint treatment application has been completed and allowed to dry. Simply lift or pierce one end of the flexible strip and pull out.

Made in the U.S.A.

Phillips is proud that all gripSTIK® vinyl beads, trims and accessories including Phillips gripSTIK® 093 E-Z Strip® Expansion Control Joint are made in the United States of America.

The information and recommendations contained herein are, to the best of Phillips Manufacturing Company's knowledge and belief, accurate and reliable as of the date issued. Phillips Manufacturing Company has no control over the conditions of handling and use, and makes no warranty regarding the results obtained from the use of this data. The information and recommendations are offered for the user's consideration and examination, and it is the user's responsibility to determine that they are suitable and complete for its particular use. Phillips reserves the right to make alterations and amendments to the detailed specifications at its discretion. Phillips disclaims responsibility for all actions, proceedings, liabilities, claims, damages, cost, losses, and expenses in relation to, or arising out of, incorrect utilization of this information.

